

---

## Unit 1 Exam

QuesNo	Question
1	<p>Knowledge Builder can be accessed from:</p> <ul style="list-style-type: none"><li>A Station Help.</li><li>B Control Builder Help</li><li>C Windows Desk Top.</li><li>D All of the above.</li></ul>
2	<p>Which of the following is the best definition for a Knowledge Builder Guide?</p> <ul style="list-style-type: none"><li>A A Knowledge Builder guide is a collection of general purpose information.</li><li>B A Knowledge Builder guide is a "look it up" manual, not to be read cover to cover.</li><li>C A Knowledge Builder guide contains "how it works" information.</li><li>D A Knowledge Builder guide is a collection of "how to" procedures.</li></ul>
3	<p>Which of the following is the best definition for a Knowledge Builder Theory Manual?</p> <ul style="list-style-type: none"><li>A A Knowledge Builder Theory Manual is a collection of general purpose information.</li><li>B A Knowledge Builder Theory Manual is a "look it up" manual, not to be read cover to cover.</li><li>C A Knowledge Builder Theory Manual contains "how it works" information.</li><li>D A Knowledge Builder Theory Manual is a collection of "how to" procedures.</li></ul>

- 
- 4 Which of the following is the best definition for a Knowledge Builder Reference Manual?
- A A Knowledge Builder Reference Manual is a collection of general purpose information.
  - B A Knowledge Builder Reference Manual is a "look it up" manual, not to be read cover to cover.
  - C A Knowledge Builder Reference Manual contains "how it works" information.
  - D A Knowledge Builder Reference Manual is a collection of "how to" procedures.
- 5 In Control Builder, to add a Control Module or make structural changes to an existing CM you must use the:
- A Project tab
  - B Monitoring tab
  - C Library tab
- 6 In Control Builder, to view CMs on line or to change parameters on line, you must use the:
- A Project tab
  - B Monitoring tab
  - C Library tab
- 7 To back up your controller data base, you must first **upload** to the Monitoring tab, then **update** to the Project tab.
- A True
  - B False

- 
- 8 From the RSLinx communication software menu you can select "Configure Drivers" to display a list of the currently configured drivers. What does it mean when the driver, AB\_PCIC-1 Cnet..., indicates Running... ?
- A You should call the Honeywell Technical Assistance Center (TAC).
  - B You need to access the device from the Windows NT Control Panel and disable the driver.
  - C You need to remove the server's ControlNet ISA Interface card and reset its jumpers according to the procedures defined in the Control Hardware Installation Guide.
  - D Your RSLinx communication software has been configured correctly on your system. Running is the expected response indicating the driver is operational.
- 9 To verify the CNet server address, from the RSLinx Communications Menu, click Configure Drivers and in the listing of Configured Drivers, double-click the line starting with "AB\_PCIC-1 CNet..." and observe the MAC ID.
- A True
  - B False
- 10 To verify the server's Ethernet adapter and IP address, from the Control Panel, Network menu, click the Protocols tab, double-click TCP/IP Protocol and from the IP Address tab, verify that your adapter is selected.
- A True
  - B False